

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013903.02-R1
DATE: 12/22/2020
CERTIFICATION PROGRAM: Structural
COMPANY: All Seasons
CODE: 353-2
REVISION DATE: 06/11/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
All Seasons Commercial Division, Inc. 400 Ambassador Row Longview, TX 75604	Series "3250 Fin Mounted" Aluminum Single Hung Window Impact Rated Configuration: O/X Glazing: IG-1/4" Annealed Glass/1/8" Annealed Glass/0.090" Eastman Saflex Interlayer/1/8" Annealed Glass Frame: W-1219mm(48") H-1905mm(75") Sash: W-1168mm(46") H-937mm(36.88") DLO: W-1111mm(43.75") H-835mm(32.88")

SPECIFICATION	PRODUCT RATING
ASTM E1996-14a ASTM E1886-13a	Design Pressure: ± 2880 Pa (± 60 psf) Wind Zone 3 - Missile Level D

Product Tested By: Construction Consulting Laboratory, International
Report No: CCLI 20-188
Expiration Date: December 31, 2030

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "MD" or similar, written over a horizontal line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023