

AUTHORIZATION FOR PRODUCT CERTIFICATION

Seal Craft
1207 Airport Dr.
Shreveport, LA 71107

Attn: Ray VanNess

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The listing below will be added to the next update of the AAMA Certified Products Directory.

SPECIFICATIONS		RECORD OF PRODUCT TESTED		
AAMA/WDMA/CSA 101/I.S.2/A440-08 AW-PG50*-1372x2350 (54x93)-FW	AAMA 506			
COMPANY AND PLANT LOCATION	Missile Level: D Rating: +50/-50, 54x93 Wind Zone: 4 Rating above conforms to requirements of: ASTM E1886 and E1996	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED
Seal Craft Code: SCM		17782	4200 FIXED DIVIDED LITE (AL) (O/O) (IG) (INS PVB LAM GL) (ASTM)	<u>FRAME (mm)</u> 1372 x 2350 (4'6" x 7'9")

1. This Certification will expire **April 23, 2023** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

2. Structural Test & Report By:

Intertek B&C

Report No: **I7857.01-801-44**

Date of Report: **November 7, 2018**

Missile Impact Test & Report by:

Intertek B&C

Report No: **I3038.01-801-44 Rev. 1**

Date of Report: **July 31, 2018 (Revised October 8, 2018)**

Evaluated for Certification: **November 19, 2018**



Associated Laboratories, Inc.

Authorized for Certification: **November 19, 2018**

SBS/JTS

American Architectural Manufacturers Association