

Hallmark® Certificate of Conformance and License (CCL)



Sierra Pacific Windows
11605 Reading Road
PO Box 8489
PO Box 8489
Red Bluff, CA 96080

Mfr ID: 436
For more Information visit www.amscert.com
Website: www.sierrapacificwindows.com
TEL: 530-527-9620

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	CertDate	ExpDate
436-H-680.28	FeelSafe H3 2.0 Direct Set 43"x 53" (Single/Multi Wide)	101/I.S.2/A440-11	Class CW-PG50; Size Tested 1084mm x 1338mm * Type-FW; DP +50/-60 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=Fixed	1084mm	1338mm	ESP027119P-2238.1	4/4/2018	12/14/2027
436-H-680.29	FeelSafe H3 2.0 Direct Set 43"x 53" (Single/Multi Wide)	ASTM E-1996 14/ASTM E-1886 13a	DP +50/-60 psf, Missile D, Wind Zone 3	1084mm	1338mm	ESP027119P-2238.1	4/4/2018	12/14/2027
436-H-680.31	FeelSafe H3 2.0 Direct Set 45"x 84" (Single/Multi Wide)	101/I.S.2/A440-11	Class CW-PG50; Size Tested 1143mm x 2134mm * Type-FW; DP +50/-60 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=Fixed	1143mm	2134mm	ESP027119P-2238.2	4/4/2018	12/14/2027
436-H-680.33	FeelSafe H3 2.0 Direct Set 45"x 84" (Single/Multi Wide)	ASTM E-1996 14/ASTM E-1886 13a	DP +50/-60 psf, Missile D, Wind Zone 3	1143mm	2134mm	ESP027119P-2238.2	4/4/2018	12/14/2027
~~436-H-680.34~~	~~FeelSafe H3 2.0 Direct Set 48"x 120" (Single/Multi Wide)~~	~~101/I.S.2/A440-11~~	~~Class CW-PG50; Size Tested 1084mm x 1338mm * Type-FW; DP +50/-60 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=Fixed~~	~~1084mm~~	~~1338mm~~	~~ESP027119P-2238.3~~	~~4/4/2018~~	~~12/14/2027~~
~~436-H-680.36~~	~~FeelSafe H3 2.0 Direct Set 48"x 120" (Single/Multi Wide)~~	~~ASTM E-1996 14/ASTM E-1886 13a~~	~~DP +50/-60 psf, Missile D, Wind Zone 3~~	~~1084mm~~	~~1338mm~~	~~ESP027119P-2238.3~~	~~4/4/2018~~	~~12/14/2027~~
436-H-680.37	FeelSafe H3 2.0 Direct Set 143"x 72"-Common Mull	101/I.S.2/A440-11	Class CW-PG50; Size Tested 3632mm x 1829mm * Type-FW; DP +50/-60 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=Fixed	3632mm	1829mm	ESP027119P-2238.4	4/4/2018	12/14/2027
436-H-680.39	FeelSafe H3 2.0 Direct Set 143"x 72"-Common Mull	ASTM E-1996 14/ASTM E-1886 13a	DP +50/-60 psf, Missile D, Wind Zone 3	3632mm	1829mm	ESP027119P-2238.4	4/4/2018	12/14/2027
436-H-680.40	FeelSafe H3 2.0 Direct Set 64"x 105" (Single/Multi-Wide)	101/I.S.2/A440-11	Class CW-PG50; Size Tested 1626mm x 2667mm Type-FW; DP +50/-60 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=Fixed	1626mm	2667mm	ESP027119P-2238.5	4/4/2018	12/14/2027
436-H-680.42	FeelSafe H3 2.0 Direct Set 64"x 105" (Single/Multi-Wide)	ASTM E-1996 14/ASTM E-1886 13a	DP +50/-60 psf, Missile D, Wind Zone 3	1626mm	2667mm	ESP027119P-2238.5	4/4/2018	12/14/2027

Hallmark® Certificate of Conformance and License (CCL)





Sierra Pacific Windows
11605 Reading Road
PO Box 8489
PO Box 8489
Red Bluff, CA 96080

Mfr ID: 436
For more Information visit www.amscert.com
Website: www.sierrapacificwindows.com
TEL: 530-527-9620

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	CertDate	ExpDate
-------------	--------------	----------	--------	------	------	---------------	----------	---------

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By:  John McFee, VP of Certification Programs, WDMA Hallmark

By:  Rhonda Schotz, Authorized Representative, AMS

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com