

Hallmark® Certificate of Conformance and License (CCL)



AMS, INC.
Administrative Management
Systems, Inc.

Sierra Pacific Windows
11605 Reading Road
PO Box 8489
PO Box 8489
Red Bluff, CA 96080

Mfr ID: 436


For more Information visit www.amscert.com


Website: www.sierrapacificwindows.com

TEL: 530-527-9620

<i>Product No.</i>	<i>Product Name</i>	<i>Standard</i>	<i>Rating</i>	<i>Wide</i>	<i>High</i>	<i>Test Report #</i>	<i>CertDate</i>	<i>ExpDate</i>
436-H-611.85	FeelSafe Aluminum Clad Outswing Door 6-4 x 8-3 Dual/Single-Through Frame Installation	101/I.S.2/A440-11	Class LC-PG65; Size Tested 1918 mm x 2502mm Type- SHD; DP +65/-70 psf; Water Test Press 470Pa (9.82psf); Can. Air Infil/Exfil. Level=A3	1918 mm	2502mm	ESP025782P-2183 R2	6/20/2018	3/7/2028
436-H-611.89	FeelSafe Aluminum Clad Outswing Door 6-4 x 8-3 Dual/Single	ASTM E-1996 14/ASTM E-1886 13a	DP +65/-70 psf, Missile D, Wind Zone 4	1918mm	2502mm	ESP025782P-2183 R2	6/20/2018	12/13/2027
436-H-611.91	FeelSafe Aluminum Clad Outswing Door 6-4 x 8-3 Dual/Single-Through Frame Installation	TAS 201/202/203-94	DP & Cycle Pressure +65/-70 psf, Large Missile	1918mm	2502mm	ESP025782P-2183.3	8/9/2018	3/17/2028

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By:  *John McFee, VP of Certification Programs, WDMA Hallmark*

By:  *Rhonda Schotz, Authorized Representative, AMS*

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com