

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014164.01
DATE: 08/06/2018
CERTIFICATION PROGRAM: Structural
COMPANY: Continental Glass
CODE: 2103-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Continental Glass Systems, LLC 325 West 74 Place Hialeah, FL 33014	Series "2800 Lift & Slide" Aluminum Sliding Glass Door w/Louvered Vent Configuration: OXO Glazing: Monolithic - 1/4" Tempered Glass/0.060" Kuraray Trosifol Interlayer/1/4" Tempered Glass/1/4" Tempered Glass/0.060" Eastman Chemical Saflex PVB Interlayer/1/4" Tempered Glass/0.060" Kuraray SentryGlas Interlayer/1/4" Tempered Glass Frame: W-3962mm(156") H-3658mm(144") DLO: W-1111mm(43.75") H-3358mm(132.19")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure: ±6703 Pa (140 psf) Positive Design Pressure: 6703 Pa (140 psf) Negative Design Pressure: 9097 Pa (190 psf) Water Penetration Resistance Test Pressure: 1005 Pa (21.00 psf) Large Missile Impact Rated Small Missile Impact Rated

Product Tested By: Blackwater Testing, Inc.
Report No: BT-CON-18-001
Expiration Date: June 30, 2022

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122