



# CERTIFICATION

6300 Enterprise Lane | Madison, WI 53719 | drjcertification.org



Issue Date: October 19, 2020

## Certificate of Code Compliance

This Certificate of Code Compliance is issued by DrJ Engineering, LLC (DrJ), within the scope of the evaluation listed below. This evaluation is based on standardized evaluation of the product conducted by DrJ, an accredited ANSI ISO/IES 17065 agency listed with the Florida Building Commission as a Product Certification Agency.

This certificate indicates the product is compliant with the Florida Building code for the scope of application.

| Manufacturer Information                                                                                  | Products Certified                        |
|-----------------------------------------------------------------------------------------------------------|-------------------------------------------|
| V2T IP, LLC<br>13000 S Tryon St Ste F-193<br>Charlotte, NC 28278-7652<br>704-900-1220<br>v2roofsystem.com | Venturi Vacuum Technology (V2T) Roof Vent |

### REFERENCED STANDARDS

ASCE 7 – 2016  
UL 1897 – 2012

### SCOPE OF EVALUATION

Performance of Venturi Vacuum Technology (V2T) Roof Vent for resistance to wind uplift forces used with modified bitumen and singly-ply roof membranes installed on low-slope roofs. Performance for use in HVHZs is approved based on the product uplift resistance of 195 psf.

### AUTHORIZED SIGNATURE

Larry Wainright | Vice President Technical Services  
DrJ Engineering, LLC  
6300 Enterprise Lane  
Madison, WI 53719  
[lwainright@drjengineering.org](mailto:lwainright@drjengineering.org)  
608-310-6742