

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014137-R2
DATE: 06/15/2018
CERTIFICATION PROGRAM: Structural
COMPANY: Nan Ya
CODE: 661-1
REVISION DATE: 03/02/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Nan Ya Plastics Corporation USA 8989 North Loop East, Suite 800 Houston, TX 77029	Series "SLPS" Glazed Fiberglass Inswing Side-Hinged Door Assembly w/Sidelites Configuration: OXX/O Glazing: IG- 1/8" Tempered Glass/1/8" Tempered Glass/0.090" Kuraray PVB Interlayer/1/8" Tempered Glass Frame: W-3720mm(146.44") H-2094mm(82.44") Panel: W-908mm(35.75") H-2013mm(79.25") DLO: W-635mm(25") H-1600mm(63")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 CSA A440S1-09 ASTM E1886-05 ASTM E1996-05/09	Class R-PG40 3720 x 2094 (146 x 82)-SHD Design Pressure: ±1915 Pa (40 psf) Positive Design Pressure: 2400 Pa (50 psf) Negative Design Pressure: 2400 Pa (50 psf) Water Penetration Resistance Test Pressure: 288 Pa (6.0 psf) Canadian Air Infiltration/Exfiltration Level: A3 Wind Zone 4 - Missile Level D

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-4103-02
Expiration Date: April 30, 2036

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023