

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013716.01-R3
DATE: 07/30/2017
CERTIFICATION PROGRAM: Structural
COMPANY: Nan Ya
CODE: 661-1
REVISION DATE: 06/19/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Nan Ya Plastics Corporation USA 4016 Shadrack St. Houston, TX 77013	Series "SLPS Lite" Glazed Fiberglass Outswing Side-Hinged Door Assembly Configuration: OXX/O Glazing: Insulated Glass (Tempered) Frame: W-3720mm(146.44") H-2469mm(97.19") Panel: W-908mm(35.75") H-2419mm(95.25") DLO: W-635mm(25") H-2007mm(79")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 CSA A440S1-09	Class LC-PG60 3720 x2469 (146 x 97)-SHD Design Pressure: ±2880 Pa (60 psf) Water Penetration Resistance Test Pressure: 432 Pa (9.0 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-4103-06
Expiration Date: April 30, 2036

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023