

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014137.02-R3  
DATE: 06/15/2018  
CERTIFICATION PROGRAM: Structural  
COMPANY: Nan Ya  
CODE: 661-1  
REVISION DATE: 06/19/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS                                                                       | PRODUCT DESCRIPTION                                                                                                                                                                                                                                                                                             |
|------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>Nan Ya Plastics Corporation USA</b><br><b>4016 Shadrack St.</b><br><b>Houston, TX 77013</b> | <b>Series "SLPS" Glazed Fiberglass</b><br><b>Inswing Side-Hinged Door Assembly</b><br><br><b>w/Sidelites</b><br><br>Configuration: OXX/O<br>Glazing: Insulating Glass (Tempered)<br><br>Frame: W-3720mm(146.44") H-2500mm(98.44")<br>Panel: W-908mm(35.75") H-2419mm(95.25")<br>DLO: W-635mm(25") H-2007mm(79") |

| SPECIFICATION                                                  | PRODUCT RATING                                                                                                                                                                                                                                                                                                             |
|----------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b><br><b>CSA A440S1-09</b> | <b>Class R-PG30 3720 x 2500 (146 x 98)-SHD</b><br><b>Design Pressure: ±1436 Pa (30 psf)</b><br><b>Positive Design Pressure: 2160 Pa (45 psf)</b><br><b>Negative Design Pressure: 2400 Pa (50 psf)</b><br>Water Penetration Resistance Test Pressure: 223 Pa (4.65 psf)<br>Canadian Air Infiltration/Exfiltration Level: A3 |

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-210-4103-04  
Expiration Date: April 30, 2036

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be "MD" or similar, written over a horizontal line.

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023