

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013310.04-R3
DATE: 09/25/2018
CERTIFICATION PROGRAM: Structural
COMPANY: Nan Ya
CODE: 661-1
REVISION DATE: 06/19/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Nan Ya Plastics Corporation USA 4016 Shadrack St. Houston, TX 77013	Series "SLPS" Outswing Glazed Fiberglass Side-Hinged Patio Door (w/Head Frame & Jamb with Weather Strip B) Configuration: OXX/O Glazing: IG-1/8" Tempered Glass/1/8" Tempered Glass/0.090" Kuraray PVB Interlayer/1/8" Tempered Glass Frame: W-3720mm(146.44") H-2062mm(81.19") Panel: W-908mm(35.75") H-2062mm(79.25") DLO: W-635mm(25") H-1600mm(63")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure: ±2400 Pa (50 psf) Water Penetration Resistance Test Pressure: 359 Pa (7.5 psf) Large Missile Impact Rated

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-4112-03
Expiration Date: July 31, 2036

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "MD".

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023