



Hallmark® Certificate of Conformance and License (CCL)



Marvin
PO Box 100
401 State Ave N.
401 State Ave N.
Warroad, MN 56763

Mfr ID: 407
For more Information visit www.amscert.com
Website: www.marvin.com
TEL: 218-386-1430

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	CertDate	ExpDate
407-H-1149.00	Ultimate Double Hung/Single Hung Insert G2 45x87	101/I.S.2/A440-11	Class LC-PG50; Size Tested 1153mm x 2215mm (45" x 87") Type-H; DP +50/-50 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A3	1153mm	2215mm	12370.01-201-47	8/6/2018	4/27/2028
WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards. By: <i>John McFee</i> John McFee, VP of Certification Programs, WDMA Hallmark By: <i>Lucas L. Wenzel</i> Lucas L. Wenzel, Authorized Representative, AMS Program Sponsor: Window and Door Manufacturers Assoc 330 N. Wabash Avenue, Suite 2000 Chicago, IL 60611 TEL (312)673-4828 www.wdma.com Program Administrator: Administrative Management Systems, Inc. PO Box 730, 205 West Main Sackets Harbor, NY 13685 TEL (315)646-2234 staff@amscert.com								