

MI Windows & Doors, LLC
P.O. Box 370
Gratz, PA 17030-0370

Attn: Rick Sawdey

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of tests by an AAMA Accredited Laboratory. The listing below will be added to the next update to the AAMA Certified Products Directory.

SPECIFICATIONS		RECORD OF PRODUCT TESTED			
AAMA/WDMA/CSA 101/I.S.2/A440-17 LC-PG55 4750x3048 (187x120)-SD	PA 201,202,203***				
COMPANY AND PLANT LOCATION	Rating: +55/-55, 187"x120" Missile Level: Large	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED	
MI Windows & Doors, LLC Code: MTL	Rating above conforms to requirements of: TAS 201,202,203***	19170	120MD/130MD/140MD SLIDING DOOR FINLESS and FLANGE (AL) (XXXO) (OG) (INS PVB LAM GL) (REINF) (ASTM)	<u>FRAME(mm)</u> 4750 x 3048 (15'7" x 10'0")	<u>PANEL(mm)</u> 1235 x 2985 (4'1" x 9'10")

1. This Certification will expire **June 16, 2025** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

2. Product Tested and Reported by:

TAS Test & Report by:

Molimo LLC

Molimo LLC

Report No.: **2261.03-106-11 R0**

Report No.: **2261.02-106-11 R2**

Date of Report: **July 21, 2020**

Date of Report: **July 31, 2020 (Revised August 25, 2020)**

*****CYCLE TIME DOES NOT MEET TAS 203, BUT DOES MEET CALCULATED CYCLE TIME PER NOTE #3
ON MIAMI-DADE COUNTY CHECKLIST #0210 FOR ENTRY DOORS*****




Evaluated for Certification: **September 10, 2020**

(Validator / Operations Administrator)



Associated Laboratories, Inc.

Authorized for Certification: **September 10, 2020**



Fenestration and Glazing Industry Alliance