



AAMA CERTIFICATION PROGRAM
An FGIA Product Certification Program



AUTHORIZATION FOR PRODUCT CERTIFICATION

MI Windows & Doors, LLC
P.O. Box 370
Gratz, PA 17030-0370

Attn: Rick Sawdey

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

SPECIFICATION	RECORD OF PRODUCT TESTED			
AAMA/WDMA/CSA 101/I.S.2/A440-11 LC-PG45-4842x3048 (191x120)-SD Negative Design Pressure = -55 psf				
COMPANY AND CODE	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED	
MI Windows & Doors, LLC Code: MTL	17380	120/130/140 SGD (AL)(OXXX)(OG)(INS GL) (MODIF)(ASTM)	FRAME 4842 mm x 3048 mm (15'11" x 10'0")	PANEL 1235 mm x 2985 mm (4'1" x 9'10")
Design Pressure (psf): +55/-55 (Pa): +2640/-2640			Water Test Pressure (psf): 6.89 (Pa): 330	


This Certification will expire **March 6, 2028 (extended from March 6, 2023 per AAMA 103-19)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

Product Tested and Reported by: **Molimo, LLC**

Report No.: **Waiver; ref. 1435.02-106-12-R1**

Date of Reports: **March 16, 2018 (Revised April 3, 2018)**

Evaluated for Certification: **February 15, 2023**


Associated Laboratories, Inc.

Authorized for Certification: **February 15, 2023**


Fenestration and Glazing Industry Alliance



(Validator / Operations Administrator)