

Hallmark® Certificate of Conformance and License (CCL)



AMS, INC.
Administrative Management
Systems, Inc.

Marvin Windows and Doors
PO Box 100
401 State Ave N.
401 State Ave N.
Warroad, MN 56763

Mfr ID: 407

For more Information visit www.amscert.com

Website: www.marvin.com

TEL: 218-386-1430

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	CertDate	ExpDate
407-H-1150.00	Modern Direct Glaze Rectangle & Polygon, 145x97 Fiberglass Aluminum Clad Fixed Window	101/I.S.2/A440-11	Class CW-PG60; Size Tested 3693mm x 2473mm Type-FW; DP +60/-60 psf; Water Test Press 580Pa (12.11psf); Can. Air Infil/Exfil. Level=Fixed	3693mm	2473mm	I3501.01-201-47	10/5/2018	4/25/2028
407-H-1150.01	Modern Direct Glaze Rectangle & Polygon, 145x97 Fiberglass Aluminum Clad Fixed Window	101/I.S.2/A440-11	Class CW-PG40; Size Tested 3693mm x 2473mm Type-FW; DP +40/-40 psf; Water Test Press 580Pa (12.11psf); Can. Air Infil/Exfil. Level=Fixed	3693mm	2473mm	I3501.03-201-47	10/5/2018	4/25/2028
407-H-1150.02	Modern Direct Glaze Rectangle & Polygon, 121x62 Fiberglass Aluminum Clad Fixed Window	101/I.S.2/A440-11	Class CW-PG60; Size Tested 3083mm x 1589mm Type-FW; DP +60/-60 psf; Water Test Press 580Pa (12.11psf); Can. Air Infil/Exfil. Level=Fixed	3083mm	1589mm	I3502.01-201-47	10/5/2018	4/25/2028
407-H-1150.03	Modern Direct Glaze Rectangle & Polygon, 121x62 Fiberglass Aluminum Clad Fixed Window	101/I.S.2/A440-11	Class CW-PG40; Size Tested 3083mm x 1589mm Type-FW; DP +40/-40 psf; Water Test Press 580Pa (12.11psf); Can. Air Infil/Exfil. Level=Fixed	3083mm	1589mm	I3502.03-201-47	10/5/2018	4/25/2028

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By: John McFee John McFee, VP of Certification Programs, WDMA Hallmark

By: Rhonda Schotz Rhonda Schotz, Authorized Representative, AMS

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com