

Hallmark® Certificate of Conformance and License (CCL)



Marvin
PO Box 100
401 State Ave N.
Warroad, MN 56763

Mfr ID: 407
For more Information visit www.amscert.com
Website: www.marvin.com
TEL: 218-386-1430

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	RptDate	CertDate	ExpDate
407-H-1151.00	Modern Multi-Slide Door Stacked 285 x 120 OX-XO	101/I.S.2/A440-08	Class LC-PG35; Size Tested 7258mm x 3048mm Type-SD; DP +35/-35 psf; Water Test Press 290Pa (6.06psf); Can. Air Infil/Exfil. Level=A2	7258mm	3048mm	I6450.01-201-44	8/6/2018	10/15/2018	7/26/2028
407-H-1151.01	Modern Multi-Slide Door Stacked 285 x 120 OX-XO	101/I.S.2/A440-11	Class LC-PG35; Size Tested 7258mm x 3048mm Type-SD; DP +35/-35 psf; Water Test Press 290Pa (6.06psf); Can. Air Infil/Exfil. Level=A2	7258mm	3048mm	I6450.01-201-44	8/6/2018	10/15/2018	7/26/2028
407-H-1151.02	Modern Multi-Slide Door Stacked HP 285 x 121 OX-XO	101/I.S.2/A440-08	Class LC-PG35; Size Tested 7258mm x 3092mm Type-SD; DP +35/-35 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A2	7258mm	3092mm	I6451.01-201-44	8/6/2018	10/15/2018	7/26/2028
407-H-1151.03	Modern Multi-Slide Door Stacked HP 285 x 121 OX-XO	101/I.S.2/A440-11	Class LC-PG35; Size Tested 7258mm x 3092mm Type-SD; DP +35/-35 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A2	7258mm	3092mm	I6451.01-201-44	8/6/2018	10/15/2018	7/26/2028
407-H-1151.04	Modern Multi-Slide Door Pocket 219 X 120 XXP	101/I.S.2/A440-08	Class LC-PG40; Size Tested 3650mm x 3048mm Type-SD; DP +40/-40 psf; Water Test Press 290Pa (6.06psf); Can. Air Infil/Exfil. Level=A2	3650mm	3048mm	I6452.01-201-44	8/6/2018	10/15/2018	7/31/2028
407-H-1151.05	Modern Multi-Slide Door Pocket 219 X 120 XXP	101/I.S.2/A440-11	Class LC-PG40; Size Tested 3650mm x 3048mm Type-SD; DP +40/-40 psf; Water Test Press 290Pa (6.06psf); Can. Air Infil/Exfil. Level=A2	3650mm	3048mm	I6452.01-201-44	8/6/2018	10/15/2018	7/31/2028
407-H-1151.06	Modern Multi-Slide Door Pocket HP 219 X 121 XXP	101/I.S.2/A440-08	Class LC-PG45; Size Tested 3650mm x 3092mm Type-SD; DP +50/-45 psf; Water Test Press 440Pa (9.19psf); Can. Air Infil/Exfil. Level=A2	3650mm	3092mm	I6453.01-201-44	8/7/2018	10/15/2018	7/31/2028
407-H-1151.07	Modern Multi-Slide Door Pocket HP 219 X 121 XXP	101/I.S.2/A440-11	Class LC-PG45; Size Tested 3650mm x 3092mm Type-SD; DP +50/-45 psf; Water Test Press 440Pa (9.19psf); Can. Air Infil/Exfil. Level=A2	3650mm	3092mm	I6453.01-201-44	8/7/2018	10/15/2018	7/31/2028

Hallmark® Certificate of Conformance and License (CCL)



Marvin
PO Box 100
401 State Ave N.
Warroad, MN 56763

Mfr ID: 407
For more Information visit www.amscert.com
Website: www.marvin.com
TEL: 218-386-1430

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	RptDate	CertDate	ExpDate
407-H-1151.08	Modern Multi-Slide Door Stacked HP 237 X 121 OX-XO	101/I.S.2/A440-08	Class LC-PG40; Size Tested 6039mm x 3092mm Type-SD; DP +40/-45 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A2	6039mm	3092mm	I8280.01-201-44	10/10/2018	10/15/2018	8/31/2028
407-H-1151.09	Modern Multi-Slide Door Stacked HP 237 X 121 OX-XO	101/I.S.2/A440-11	Class LC-PG40; Size Tested 6039mm x 3092mm Type-SD; DP +40/-45 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A2	6039mm	3092mm	I8280.01-201-44	10/10/2018	10/15/2018	8/31/2028
407-H-1151.10	Modern Multi-Slide Door Stacked HP 143 X 121 OX	101/I.S.2/A440-08	Class LC-PG45; Size Tested 3650mm x 3092mm Type-SD; DP +45/-45 psf; Water Test Press 440Pa (9.19psf); Can. Air Infil/Exfil. Level=A2	3650mm	3092mm	I8281.01-201-44	9/24/2018	10/15/2018	8/30/2028
407-H-1151.11	Modern Multi-Slide Door Stacked HP 143 X 121 OX	101/I.S.2/A440-11	Class LC-PG45; Size Tested 3650mm x 3092mm Type-SD; DP +45/-45 psf; Water Test Press 440Pa (9.19psf); Can. Air Infil/Exfil. Level=A2	3650mm	3092mm	I8281.01-201-44	9/24/2018	10/15/2018	8/30/2028
407-H-1151.12	Modern Multi-Slide Door Stacked 187X120 XOX	101/I.S.2/A440-11	Class LC-PG40; Size Tested 4772mm (187-7/8") x 3048mm (120") Type-SD; DP +40/-40 psf; Water Test Press 290Pa (6.06psf); Can. Air Infil/Exfil. Level=A2	4772mm (187-7/8")	3048mm (120")	Q7326.01-201-47	1/17/2024	2/16/2024	11/3/2033
407-H-1151.13	Modern Multi-Slide Door Stacked 187X120 XOX	101/I.S.2/A440-17	Class LC-PG40; Size Tested 4772mm (187-7/8") x 3048mm (120") Type-SD; DP +40/-40 psf; Water Test Press 290Pa (6.06psf); Can. Air Infil/Exfil. Level=A2	4772mm (187-7/8")	3048mm (120")	Q7326.01-201-47	1/17/2024	2/16/2024	11/3/2033
407-H-1151.14	Modern Multi-Slide Door Stacked 187X120 XOX High Performance Sill	101/I.S.2/A440-11	Class LC-PG40; Size Tested 4772mm (187-7/8") x 3048mm (120") Type-SD; DP +40/-40 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A2	4772mm (187-7/8")	3048mm (120")	Q7692.01-201-47	1/17/2024	2/16/2024	11/17/2033

Hallmark® Certificate of Conformance and License (CCL)



Marvin
PO Box 100
401 State Ave N.
Warroad, MN 56763

Mfr ID: 407
For more Information visit www.amscert.com
Website: www.marvin.com
TEL: 218-386-1430

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	RptDate	CertDate	ExpDate
407-H-1151.15	Modern Multi-Slide Door Stacked 187X120 XOX High Performance Sill	101/I.S.2/A440-17	Class LC-PG40; Size Tested 4772mm (187-7/8") x 3048mm (120") Type-SD; DP +40/-40 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A2	4772mm (187-7/8")	3048mm (120")	Q7692.01-201-47	1/17/2024	2/16/2024	11/17/2033
407-H-1151.16	Modern Multi-Slide Door Stacked 355 X120 5 panel, 3 track	101/I.S.2/A440-11	Class LC-PG40; Size Tested 9022mm (355-3/16") x 3048mm (120") Type-SD; DP +40/-40 psf; Water Test Press 290Pa (6.06psf); Can. Air Infil/Exfil. Level=A2	9022mm (355-3/16")	3048mm (120")	Q6761.01-201-44	2/1/2024	2/16/2024	12/13/2033
407-H-1151.17	Modern Multi-Slide Door Stacked 355 X120 5 panel, 3 track	101/I.S.2/A440-17	Class LC-PG40; Size Tested 9022mm (355-3/16") x 3048mm (120") Type-SD; DP +40/-40 psf; Water Test Press 290Pa (6.06psf); Can. Air Infil/Exfil. Level=A2	9022mm (355-3/16")	3048mm (120")	Q6761.01-201-44	2/1/2024	2/16/2024	12/13/2033
407-H-1151.18	Modern Multi-Slide Door Stacked HP 355 X120 5 panel, 3 track	101/I.S.2/A440-11	Class LC-PG40; Size Tested 9022mm (355-3/16") x 3048mm (120") Type-SD; DP +40/-40 psf; Water Test Press 290Pa (6.06psf); Can. Air Infil/Exfil. Level=A2	9022mm (355-3/16")	3048mm (120")	S4059.01-201-47-R1	6/11/2025	7/15/2025	12/4/2034
407-H-1151.19	Modern Multi-Slide Door Stacked HP 355 X120 5 panel, 3 track	101/I.S.2/A440-17	Class LC-PG40; Size Tested 9022mm (355-3/16") x 3048mm (120") Type-SD; DP +40/-40 psf; Water Test Press 290Pa (6.06psf); Can. Air Infil/Exfil. Level=A2	9022mm (355-3/16")	3048mm (120")	S4059.01-201-47-R1	6/11/2025	7/15/2025	12/4/2034
407-H-1151.20	Modern Multi-Slide Door Stacked/Pocket Configurations up to 12' tall	I.S.11	Class R- PG Varies; Size Tested width varies x 3658mm (144") * Type-SD; DP Varies; Water Test Press 180Pa (3.76psf); Can. Air Infil/Exfil. Level=A2	varies	3658mm (144")	EvalReport MMSD Analysis	10/16/2025	10/28/2025	7/26/2028

Hallmark® Certificate of Conformance and License (CCL)




AMS, INC.
Administrative Management
Systems, Inc.

Marvin
PO Box 100
401 State Ave N.
Warroad, MN 56763

Mfr ID: 407
For more Information visit www.amscert.com
Website: www.marvin.com
TEL: 218-386-1430

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	RptDate	CertDate	ExpDate
-------------	--------------	----------	--------	------	------	---------------	---------	----------	---------

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By:  John McFee, VP of Certification Programs, WDMA Hallmark

By:  Lucas L. Wenzel, Authorized Representative, AMS

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com