

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014182-R3
DATE: 08/21/2018
CERTIFICATION PROGRAM: Structural
COMPANY: Bator
CODE: 2452-1
REVISION DATE: 02/02/2022

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Bator North America, LLC 1451 S. Elm-Eugene Street, Suite 2211 Greensboro, NC 27406	Series "Bator Hurricane Four Fold Door" Steel Bi-Folding Door Assembly Configuration: XXXX Glazing: IG-1/4" Tempered Glass/1/4" Heat Strengthened Glass/0.090" DuPont SentryGlas Interlayer/1/4" Heat Strengthened Glass Frame: W-4807mm(189.25") H-4877mm(192") Panel: W-1045mm(41.13") H-4832mm(190.25") DLO: W-838mm(33") H-1473mm(58")

SPECIFICATION	PRODUCT RATING
TAS 201-94 TAS 202-94 (Structural Only) TAS 203-94	Design Pressure: ±5746 Pa (120 psf) Large Missile Impact Rated

Product Tested By: Underwriters Laboratories, LLC
Report No: SV30749-20180601
Expiration Date: May 31, 2032

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122