

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014264.01-R1
DATE: 11/15/2018
CERTIFICATION PROGRAM: Structural
COMPANY: ViWinTech
CODE: 583-1
REVISION DATE: 03/31/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
ViWinTech Windows & Doors 2400 Irvin Cobb Drive Paducah, KY 42003	Series "Shoreline" Out-Swing Vinyl Casement Window New Construction /Equal Leg/Flange Frame Configuration: X Glazing: Insulating Glass-Laminate Glass- 1/8" Annealed Glass/0.090" PVB Kuraray®/ 1/8" Annealed Glass Frame: W-914mm(36") H-1829mm(72") Vemt: W-851mm(33.5") H-1769mm(69.62") DLO: W-768mm(30.25") H-1686mm(66.38")

SPECIFICATION	PRODUCT RATING
AAMA 506-16 ASTM E1886-13a/E1996-14a AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08	Design Pressure: ±2400 Pa (50 psf) Wind Zone 3-Missile Level D Class LC-PG60 914 x 1829 (36 x 72)-C Water Penetration Resistance Test Pressure: 440 Pa (9.18 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: Intertek
Report No: I8770.02-501-47
Expiration Date: September 30, 2026

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

e-mail: nami@namiinc.com