

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014265-R1
DATE: 11/15/2018
CERTIFICATION PROGRAM: Structural
COMPANY: ViWinTech
CODE: 583-1
REVISION DATE: 03/31/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
ViWinTech Windows & Doors 2400 Irvin Cobb Drive Paducah, KY 42003	Series "Shoreline" Vinyl Project-Out Awning Window New Construction /Equal Leg/Flange Frame Configuration: X Glazing: Insulating Glass-1/8" Annealed Glass or Laminate Glass-1/8" Annealed Glass/0.090" PVB Kuraray®/1/8" Annealed Glass Frame: W-1346mm(53") H-914mm(36") Vemt: W-1283mm(50.5") H-851mm(33.5") DLO: W-1200mm(47.25") H-768mm(30.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05 CSA A440S1-09	Class LC-PG50 1346 x 914 (53 x 36)-AP Design Pressure: 2400 Pa (50 psf) Negative Design Pressure: 2880 Pa (60 psf)¹ Negative Design Pressure: 3360 (70 psf)² Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf) Canadian Air Infiltration/Exfiltration Level: A3

¹Specimen 1/²Specimen 2,3,4

Product Tested By: Intertek
Report No: I8713.02-501-47
Expiration Date: September 30, 2026

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
e-mail: nami@namiinc.com