

Hallmark® Certificate of Conformance and License (CCL)



AMS, INC.
Administrative Management
Systems, Inc.

Loewen Windows
77 Hwy 52 West
Steinbach, MB R5G 1B2

Mfr ID: 415

For more Information visit www.amscert.com

Website: www.loewen.com

TEL:

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	CertDate	ExpDate
415-H-789.09	Aluminum Clad Wood Outswing Side-Hinged Terrace Door (XO)	101/I.S.2/A440-11	Class LC-PG40; Size Tested 1800mm (70 7/8") x 2516mm (99") Type-SHD; DP +40/-40 psf; Water Test Press 330Pa (6.89psf); Can. Air Infil/Exfil. Level=A3	1800mm	2516mm	UL-SV30624-20160714-R#3	9/21/2016	7/14/2026

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By: John McFee John McFee, VP of Certification Programs, WDMA Hallmark

By: Rhonda Schotz Rhonda Schotz, Authorized Representative, AMS

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com