

Hallmark® Certificate of Conformance and License (CCL)



AMS, INC.
Administrative Management
Systems, Inc.

Loewen Windows
77 Hwy 52 West
Steinbach, MB R5G 1B2

Mfr ID: 415


For more Information visit www.amscert.com


Website: www.loewen.com

TEL:

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	RptDate	CertDate	ExpDate
415-H-789.11	Aluminum Clad Wood Outswing Side-Hinged Terrace Door (XO)	101/I.S.2/A440-11	Class LC-PG30; Size Tested 1800mm x 3126mm Type-SHD; DP +30/-30 psf; Water Test Press 330Pa (6.89psf); Can. Air Infil/Exfil. Level=A3	1800mm	3126mm	SV30624-20160714-Report7	9/2/2016	9/21/2016	3/2/2028

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By:  John McFee, VP of Certification Programs, WDMA Hallmark

By:  Lucas L. Wenzel, Authorized Representative, AMS

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com