



AAMA CERTIFICATION PROGRAM
An FGIA Product Certification Program



AUTHORIZATION FOR PRODUCT CERTIFICATION

Winco Window Company
6200 Maple Ave.
St. Louis, MO 63130

Attn: Lothar Erkens

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

SPECIFICATIONS		RECORD OF PRODUCT TESTED		
AAMA/WDMA/CSA 101/I.S.2/A440-08 AW-PG90-1524x2515 (60x99)-FW	PA 201, 202, 203			
COMPANY AND CODE	Missile Level: Large Rating: +90/-90, 60x99	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED
Winco Window Company Code: WWC	Rating above conforms to the requirements of: TAS 201, TAS 202, and TAS 203	18133	3250 FIXED (AL)(O)(OG) (INS H.S./0.090" PVB LAM GL)(ASTM)	FRAME 1524 mm x 2515 mm (5'0" x 8'3")

This Certification will expire **November 16, 2028 (extended from November 16, 2023 per AAMA 103-19)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

Structural Test & Report By:

UL, LLC

Report No: **SV30610-20181116-R3**

Date of Report: **December 6, 2018**
(Revised March 18, 2019)


Missile Impact Test & Report By:

UL, LLC


Report No: **SV30610-20181116-R3**

Date of Report: **December 6, 2018**
(Revised March 18, 2019)

Evaluated for Certification: **October 4, 2023**


Associated Laboratories, Inc.

Authorized for Certification: **October 4, 2023**


Fenestration and Glazing Industry Alliance



(Validator / Operations Administrator)