

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014231.07-R3  
DATE: 10/04/2018  
CERTIFICATION PROGRAM: Structural  
COMPANY: Wincore  
CODE: 1640-1  
REVISION DATE: 02/23/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS                                                                           | PRODUCT DESCRIPTION                                                                                                                                                                                                                                                                           |
|----------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>Wincore Window Company, LLC</b><br><b>250 Staunton Turnpike</b><br><b>Parkersburg, VA 26104</b> | <b>Opaque Inswing Fiberglass</b><br><b>Side-Hinged Door w/Sidelites</b><br><br><b>“Non-Impact”</b><br><br>Configuration: OXO<br>Glazing: Insulating Glass (Tempered)<br><br>Frame: W-1740mm(68.5") H-2178mm(85.75")<br>Panel: W-908mm(35.75") H-2108mm(83")<br>DLO: W-152mm(6") H-1600mm(63") |

| SPECIFICATION          | PRODUCT RATING                                                                                                                                      |
|------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>ASTM E330-02/14</b> | <b>Design Pressure: ±2873 Pa (60 psf)</b><br><b>Positive Design Pressure: 2873 Pa (60 psf)</b><br><b>Negative Design Pressure: 3352 Pa (70 psf)</b> |

Product Tested By: Testing Evaluation Laboratories, Inc.  
Report No: TEL 02801776/W-1926  
Expiration Date: **September 30, 2028**

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)