

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014231-R3
DATE: 10/04/2018
CERTIFICATION PROGRAM: Structural
COMPANY: Wincore
CODE: 1640-1
REVISION DATE: 02/23/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Wincore Window Company, LLC 250 Staunton Turnpike Parkersburg, VA 26104	Opaque Inswing Fiberglass Side-Hinged Door w/Transom “Non-Impact” Configuration: O/X Glazing: Insulating Glass (Tempered) Frame: W-953mm(37.5") H-2788mm(109.75") Panel: W-908mm(35.75") H-2108mm(83") DLO: W-876mm(34.5") H-533mm(21")

SPECIFICATION	PRODUCT RATING
ASTM E330-02/14	Design Pressure: ±3352 Pa (70 psf) Positive Design Pressure: 3352 Pa (70 psf) Negative Design Pressure: 3591 Pa (75 psf)

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL 02801770/W-1926
Expiration Date: September 30, 2028

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com