

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014231.24-R2
DATE: 10/23/2018
CERTIFICATION PROGRAM: Structural
COMPANY: Wincore
CODE: 1640-1
REVISION DATE: 02/12/2020

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Wincore Window Company, LLC 250 Staunton Turnpike Parkersburg, VA 26104	Opaque Outswing Fiberglass Door w/Sidelites & Transom "Non-Impact" Configuration: O/OXO Glazing: Insulating Glass (Tempered) Frame: W-1892mm(74.5") H-3073mm(121") Panel: W-1060mm(41.75") H-2413mm(95") DLO: W-1816mm(71.50") H-533mm(21")

SPECIFICATION	PRODUCT RATING
ASTM E330-02/14	Design Pressure: ±2155Pa (45 psf) Qualifies Configurations: O/X/XO/OX/OXO/O/O/O/O/XO/O/OX/O/OXO

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL 02801791/W-1926
Expiration Date: September 30, 2024

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122