


Hallmark® Certificate of Conformance and License (CCL)



Pella Corporation
102 Main Street
Pella, IA 50219

Mfr ID: 411
For more Information visit www.amscert.com
Website: www.pella.com
TEL: 641-621-6096

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	CertDate	ExpDate
411-H-1499.10	Architect Series and Architect Series Reserve Contemporary Multi-Slide Door	101/I.S.2/A440-11	Class R-PG20; Size Tested 6096mm x 3035mm Type-SD; DP +20/-25 psf; Water Test Press 150Pa (3.13psf); Can. Air Infil/Exfil. Level=A2	6096mm	3035mm	ESP029962P.3	2/27/2019	2/8/2029
411-H-1499.11	Architect Series and Architect Series Reserve Contemporary Multi-Slide Door	101/I.S.2/A440-17	Class R-PG20; Size Tested 6096mm x 3035mm Type-SD; DP +20/-25 psf; Water Test Press 150Pa (3.13psf); Can. Air Infil/Exfil. Level=A2	6096mm	3035mm	ESP029962P.3	2/27/2019	2/8/2029

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By: John McFee John McFee, VP of Certification Programs, WDMA Hallmark

By: Lucas L. Wenzel Lucas L. Wenzel, Authorized Representative, AMS

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com