

Hallmark® Certificate of
Conformance and License (CCL)AMS, INC.
Administrative Management
Systems, Inc.Pella Corporation
102 Main Street
Pella, IA 50219

Mfr ID: 411

For more information visit www.amscert.comWebsite: www.pella.com

TEL: 641-621-6096

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	CertDate	ExpDate
411-H-1499.19	Architect Series and Architect Series Reserve Contemporary Multi-Slide Door	101/I.S.2/A440-11	Class LC-PG35; Size Tested 10554mm x 2438mm Type-SD; DP +45/-45 psf; Water Test Press 260Pa (5.43psf); Can. Air Infil/Exfil. Level=A3	10554mm	2438mm	ESP029962P.6	7/11/2019	6/10/2029
411-H-1499.20	Architect Series and Architect Series Reserve Contemporary Multi-Slide Door	101/I.S.2/A440-17	Class LC-PG35; Size Tested 10554mm x 2438mm Type-SD; DP +45/-45 psf; Water Test Press 260Pa (5.43psf); Can. Air Infil/Exfil. Level=A3	10554mm	2438mm	ESP029962P.6	7/11/2019	6/10/2029

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By: John McFee John McFee, VP of Certification Programs, WDMA HallmarkBy: Lucas L. Wenzel Lucas L. Wenzel, Authorized Representative, AMSProgram Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.comProgram Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com