

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI014489-R2  
**DATE:** 08/19/2019  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Masonite  
**CODE:** 703-1  
**REVISION DATE:** 11/14/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS                                                                 | PRODUCT DESCRIPTION                                                                                                                                                                                                                                                                                                                                                               |
|------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>Masonite International</b><br><b>1955 Powis Road</b><br><b>West Chicago, IL 60185</b> | <b>Glazed Outswing Wood-Edge Fiberglass</b><br><b>Side-Hinged Double Door Assembly</b><br><b>(Plugless Snap Fit Glazed)</b><br><br>Configuration: OXXO<br>Glazing: Insulating Glass (Tempered)<br><br>Frame: W-2667mm(105") H-2048mm(80.63")<br>Panel: W-908mm(35.75") H-2013mm(79.25")<br><br>(2) Door DLO: W-152mm(6") H-1600mm(63")<br>Sidelite DLO: W-152mm(6") H-1600mm(63") |

| SPECIFICATION               | PRODUCT RATING                                                                                                                                                      |
|-----------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>ASTM E330-02/14/M-14</b> | <b>Design Pressure: <math>\pm 2155</math> Pa (45 psf)</b><br><b>Positive Design Pressure: 2155 Pa (45 psf)</b><br><b>Positive Design Pressure: 2400 Pa (50 psf)</b> |

Product Tested By: American Test Lab, Inc. (ATLNC)  
Report No: ATLNC 0319.01-19/W-2094  
Expiration Date: May 31, 2027

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)