NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI014489.09-R2**
DATE:	**08/19/2019**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Masonite**
CODE:	**703-1**
REVISION DATE:	**11/14/2023**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Masonite International **1955 Powis Road** **West Chicago, IL 60185**	**Opaque Outswing Wood-Edge Fiberglass** **Side-Hinged Double Door Assembly** **(Plugless Snap Fit Glazed)** Configuration:OXXO Glazing: Insulating Glass (Tempered) Frame: W-2667mm(105") H-2454mm(96.63") Panel: W-908mm(35.75") H-2419mm(95.25") DLO: W-152mm(6") H-1600mm(63")

SPECIFICATION	PRODUCT RATING
ASTM E330-02/14/M-14	**Design Pressure: 2400 Pa (50 psf)**

Product Tested By: American Test Lab, Inc. (ATLNC)
Report No: ATLNC 0321.01-19/W-2094
Expiration Date: **May 31, 2027**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com