

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013657-R4
DATE: 03/14/2017
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1
DATE: 06/26/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Architectural Fiberglass Glazed Inswing Double Door w/Sidelites Configuration: OXXO Glazing: Insulating Glass (Tempered) Frame: W-2924mm(115.13") H-2076mm(81.75") Panel: W-908mm(35.75") H-2007mm(79") DLO: W-536mm(21.12") H-1603mm(63.12")

SPECIFICATION	PRODUCT RATING
ASTM E330-02	Design Pressure: 2633 Pa (55 psf) Negative Design Pressure: 2873 Pa (60 psf)

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL 01681762/W-1848
Expiration Date: March 31, 2032

Administrator's Signature: 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023