

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013685.13-R4
DATE: 04/17/2017
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1
REVISION DATE: 06/25/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Mastergrain Entry Door" Architectural Fiberglass Opaque Outswing Side-Hinged Double Door w/Mulled Sidelites Configuration: OXXO Glazing: IG-1/8" Tempered Glass/1/8" Annealed Glass/0.090" Saflex PVB Interlayer/1/8" Annealed Glass Frame: W-3791mm(149.25") H-2461mm(96.88") Panel: W-908mm(35.75") H-2413mm(95") DLO: W-521mm(20.5") H-1988mm(78.25")

SPECIFICATION	PRODUCT RATING
ASTM E330-02/E331-00/E283-04 ASTM E1886-05 ASTM E1996-09	Design Pressure: 2394 Pa (50 psf) Negative Design Pressure: 2394 Pa (50 psf) Water Penetration Resistance Test Pressure: 395 Pa (8.25 psf) Wind Zone 4 - Missile Level D

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL 01681715/W-1849
Expiration Date: April 30, 2032

Administrator's Signature: 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023