

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013685.16-R3
DATE: 04/17/2017
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1
REVISION DATE: 06/25/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Craftsman" Architectural Fiberglass Glazed Inswing Side-Hinged Door Configuration: X Glazing: IG-1/4" Tempered Glass/3/16" Annealed Glass/0.090" Saflex PVB Interlayer/3/16" Annealed Glass Frame: W-953mm(37.5") H-2083mm(82") Panel: W-908mm(35.75") H-2007mm(79") DLO: W-578mm(20.75") H-356mm(14")

SPECIFICATION	PRODUCT RATING
ASTM E330-02/E331-00/E283-04 ASTM E1886-05 ASTM E1996-09	Design Pressure: 3112 Pa (65 psf) Negative Design Pressure: 3352 Pa (70 psf) Water Penetration Resistance Test Pressure: 0 Pa (0 psf) Wind Zone 4 - Missile Level D

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL 01681715
Expiration Date: April 30, 2032

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com

NOP C-3/30/2023