

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013987.01-R2
DATE: 09/10/2019
CERTIFICATION PROGRAM: Structural
COMPANY: Quaker
CODE: 031-1
REVISION DATE: 09/30/2019

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Quaker Window Products 504 Highway 63 South Freeburg, MO 65035	Series "M700 Modern-Vu" Aluminum Sliding Door Configuration: XO Glazing: IG-Int-Laminate-1/8" Annealed Glass/ 0.090" SentryGlas by Kuraray/1/8" Annealed Glass/ Ext-1/4" Tempered Glass Frame: W-3124mm(123") H-2438mm(96") Panel: W-1549mm(61") H-2315mm(91.13") DLO: W-1413mm(55.63") H-2184mm(86")

SPECIFICATION	PRODUCT RATING
AAMA 506-16 AAMA/WDMA/CSA 101/I.S.2/A440-08 ASTM E1886-13a/ASTM E1996-14a	Class AW-PG50 3124 x 2438 (123 x 96)-SD Design Pressure: ± 2400 Pa (50 psf) Wind Zone 4-Missile Level D Water Penetration Resistance Test Pressure: 580 Pa (12.11 psf)

Product Tested By: Intertek
Report No: H4941.01-801-44-R2/I0575.01-801-47-R2
Expiration Date: November 30, 2029

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shu".

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122