

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI013907.14-R3  
**DATE:** 07/01/2019  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** JELD-WEN  
**CODE:** 1822-1  
**REVISION DATE:** 07/29/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS                                                                    | PRODUCT DESCRIPTION                                                                                                                                                                                                                                                                                                                 |
|---------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>JELD-WEN</b><br><br><b>3737 Lakeport Boulevard</b><br><br><b>Klamath Falls, OR 97601</b> | <b>Series "Architectural Fiberglass"</b><br><br><b>Glazed Fiberglass Out-Swing</b><br><br><b>Transom</b><br><br>Configuration:<br>Glazing: IG-1/8" Annealed Glass/0.090" Kuraray PVB<br>Interlayer/1/8" Annealed Glass/1/8" Tempered Glass/<br><br>Frame: W-2524mm(99.37") H-619mm(24.38")<br>DLO: W-2457mm(96.75") H-552mm(21.75") |

| SPECIFICATION                                                                                                                                     | PRODUCT RATING                                                                                                                                                                                                                                                       |
|---------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>TAS 202-94</b><br><b>ASTM E283-04(2012)</b><br><b>ASTM E330-14/ASTM E547-00(2016)</b><br><b>ASTM E1886-05/13a</b><br><b>ASTM E1996-12a/14a</b> | <b>Design Pressure: ±3120 Pa (65 psf)</b><br><b>Positive Design Pressure: 3120 Pa (65 psf)</b><br><b>Negative Design Pressure: 3360 Pa (70 psf)</b><br><b>Water Penetration Resistance Test Pressure: 510 Pa (10.65 psf)</b><br><b>Wind Zone 3 - Missile Level D</b> |

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-310-19-065/NCTL-310-19-061  
Expiration Date: June 30, 2030

Administrator's Signature: 

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023