

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014461-R1
DATE: 07/17/2019
CERTIFICATION PROGRAM: Structural
COMPANY: Shwinco
CODE: 1972-1
REVISION DATE: 04/03/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Shwinco Architectural Products, LLC 171 Jet Services Way Dothan, AL 36303	Series "9700 4-Track" Vinyl Sliding Glass Door Configuration: OXXX-A-XXXO Glazing: IG-3/16" Tempered Glass/3/16" Heat Strengthened Glass/0.075" Saflex Vanceva Interlayer/3/16" Heat Strengthened Glass Frame: W-9741mm(383.5") H-2424mm(95.5") Vent: W-1308mm(51.5") H-2356mm(92.7") DLO: W-1032mm(40.63") H-2080mm(81.88")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 ASTM E1886-13a/ASTM E1996-14a TAS 201/202/203-94	Class LC-PG50 9741 x 2426 (384 x 96)-SD Design Pressure: ±2394 Pa (50 psf) Water Penetration Resistance Test Pressure: 400 Pa (8.35 psf) Wind Zone 4-Missile Level D Large Missile Impact Rated

Product Tested By: UL, LLC
Report No: SV31355-20190517-A
Expiration Date: May 31, 2033

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com