NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI014461.02-R1**
DATE:	**07/17/2019**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Shwinco**
CODE:	**1972-1**
REVISION DATE:	**04/03/2023**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Shwinco Architectural Products, LLC **171 Jet Services Way** **Dothan, AL 36303**	**Series "9700 4-Track"** **Vinyl Sliding Glass Door** Configuration: OXXX Glazing: IG-3/16" Tempered Glass/3/16" Heat Strengthened Glass/0.075" Saflex Vanceva Interlayer/3/16" Heat Strengthened Glass Frame: W-4883mm(192.25") H-2426mm(95.5") Vent: W-1308mm(51.5") H-2356mm(92.75") DLO: W-1032mm(40.63") H-2080mm(81.88")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 **AAMA/WDMA/CSA 101/I.S.2/A440-11** **ASTM E1886-13a/ASTM E1996-14a** **TAS 201/202/203-94**	**Class LC-PG65 4883 x 2426 (192 x 96)-SD** **Design Pressure: ±3112 Pa (65 psf)** **Water Penetration Resistance Test Pressure: 510 Pa (10.65 psf)** **Wind Zone 4-Missile Level D** **Large Missile Impact Rated**

Product Tested By: UL, LLC
Report No: SV31355-20190517-C
Expiration Date: **May 31, 2033**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com