

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015636  
DATE: 07/12/2022  
CERTIFICATION PROGRAM: Structural  
COMPANY: Croft  
CODE: 1887-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Croft, LLC</b> <b>1800 North Clark Avenue</b> <b>Magnolia, MS 39652</b>	<b>Series "22"</b> <b>Vinyl Horizontal Sliding Window</b>  Configuration: XO Glazing: Insulating Glass (Annealed)  Frame: W-1524mm(60") H-1524mm(60") Sash: W-738mm(29.09") H-1456mm(57.31") DLO: W-667mm(26.25") H-1378mm(54.25")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b>	<b>Class R-PG25 1524 x 1524 (60 x 60)-HS</b> <b>Design Pressure: ±1200 Pa (25 psf)</b> Water Penetration Resistance Test Pressure: 180 Pa (3.76 psf)

Product Tested By: PRI Construction Materials Technologies, LLC  
Report No: 2189T0010.03  
Expiration Date: **July 31, 2026**

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

[nami@namiinc.com](mailto:nami@namiinc.com)