

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014569.01-R1
DATE: 12/05/2019
CERTIFICATION PROGRAM: Structural
COMPANY: Continental Glass
CODE: 2103-1
REVISION DATE: 11/16/2020

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Continental Glass Systems, LLC 325 West 74 Place Hialeah, FL 33014	Series "3814" Aluminum Window Wall System Configuration: O/O/O/OO/O/O/OO/O/O/OO/O/O/O (w/90° Bend Between Panels 3 & 4) Glazing: IG-1/4" Tempered Glass/1/4" Heat Strengthened Glass/0.090" Sentryglas Interlayer/1/4" Heat Strengthened Glass Frame: W-7987mm(314.44") H-7442mm(293") DLO: W-1421mm(55.94") H-2953mm(116.25")

SPECIFICATION	PRODUCT RATING
AAMA 501-15 TAS 201/202/203-94	Design Pressure: ±5746 Pa (120 psf) Water Penetration Resistance Test Pressure: 862 Pa (18 psf) Large Missile Impact Rated

Product Tested By: Blackwater Testing, Inc.
Report No: BT-CON-19-013/W-1973
Expiration Date: September 30, 2023

A handwritten signature in black ink, appearing to be "S. D.", written over a horizontal line.

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122