WINDOW & DOOR MANUFACTURERS ASSOCIATION
WDMA

Hallmark® Certificate of Conformance and License (CCL)

AMS, INC.
Administrative Management Systems, Inc.

Sierra Pacific Windows
11605 Reading Road
PO Box 8489
PO Box 8489
Red Bluff, CA 96080

Mfr ID: 436
For more Information visit www.amscert.com
Website: www.sierrapacificwindows.com
TEL: 530-527-9620

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	CertDate	ExpDate
436-H-611.99	Aluminum Clad Outswing Door 6-4 x 8-3 Dual Handle Activated-Upgrade	101/I.S.2/A440-17	Class LC-PG35; Size Tested 1918mm x 2502mm * Type-SHD; DP +35/-35 psf; Water Test Press 260Pa (5.43psf); Can. Air Infil/Exfil. Level=A2	1918mm	2502mm	ESP027421P-2248	12/4/2018	1/25/2027
436-H-611.100	Aluminum Clad Outswing Door 6-4 x 8-3 Dual Handle Activated-Upgrade	101/I.S.2/A440-11	Class LC-PG35; Size Tested 1918mm x 2502mm * Type-SHD; DP +35/-35 psf; Water Test Press 260Pa (5.43psf); Can. Air Infil/Exfil. Level=A2	1918mm	2502mm	ESP027421P-2248	12/3/2018	1/25/2027

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By: *John McFee, VP of Certification Programs, WDMA Hallmark*

By: *Lucas L. Wenzel, Authorized Representative, AMS*

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com