NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI016194-R1**
DATE:	**05/20/2024**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Renaissance**
CODE:	**2592-1**
REVISION DATE:	**07/23/2024**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Renaissance Windows & Doors, Inc. **13340 International Parkway** **Jacksonville, FL 32218**	**Series "8700"** **Vinyl Single Hung Window** **(Retrofit Frame)** Configuration: O/X Glazing: Insulating Glass (Annealed) Frame: W-1372mm(54") H-1930mm(76") Sash: W-1303mm(51.31") H-889mm(35") DLO: W-1224mm(48.19") H-810mm(31.88")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	**Class R-PG40 1372 x 1930 (54 x 76)-H** **Design Pressure: ±1920 Pa (±40 psf)** **Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)**

Product Tested By: PRI Construction Materials Technologies, LLC
Report No: 2616T0005
Expiration Date: **March 31, 2028**

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com