

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014535.02-R1
DATE: 10/17/2019
CERTIFICATION PROGRAM: Structural
COMPANY: Renaissance
CODE: 2592-1
REVISION DATE: 06/15/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Renaissance Windows & Doors, Inc. 13340 International Parkway Jacksonville, FL 32218	Series "8500" Twin Vinyl Single Hung Window Configuration: O/X O/X Glazing: Insulating Glass (Annealed) Frame: W-2451mm(96.5") H-1829mm(72") Sash: W-1156mm(45.5") H-889mm(35") DLO: W-1099mm(43.25") H-819mm(32.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08	Class R-PG35 2451 x 1829 (97 x 72)-H Design Pressure: ± 1680 Pa (± 35 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.5 psf)

Product Tested By: National Certified Testing Laboratories, Inc.
Report No: NCTL-210-4105-04
Expiration Date: October 31, 2027

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com