

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014536-R1
DATE: 10/17/2019
CERTIFICATION PROGRAM: Structural
COMPANY: Renaissance
CODE: 2592-1
REVISION DATE: 06/15/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Renaissance Windows & Doors, Inc. 13340 International Parkway Jacksonville, FL 32218	Series "8500" Vinyl Horizontal Sliding Window Configuration: XOX Glazing: Insulating Glass (Annealed) Frame: W-2762mm(108.75") H-1524mm(60") Vent: W-892mm(35.13") H-1454mm(57.25") DLO: W-813mm(32") H-1378mm(54.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08	Class R-PG30 2762 x 1524* (109 x 60*)-HS Design Pressure: ±1436 Pa (±30 psf) Water Penetration Resisitance Test Pressure: 215 Pa (4.5 psf)

Product Tested By: National Certified Testing Laboratories, Inc.
Report No: NCTL-210-4105-03/02-51846.01
Expiration Date: **October 31, 2027**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com