

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014539-R1
DATE: 10/17/2019
CERTIFICATION PROGRAM: Structural
COMPANY: Renaissance
CODE: 2592-1
REVISION DATE: 06/15/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Renaissance Windows & Doors, Inc. 13340 International Parkway Jacksonville, FL 32218	Series "9700" Vinyl Horizontal Slider Window Configuration: OX Glazing: IG-1/8" Annealed Glass/0.090" Kuraray PVB Interlayer/1/8" Annealed Glass/1/8" Annealed Glass Frame: W-1600mm(63") H-1118mm(44") Vent: W-781mm(30.75") H-1048mm(41.25") DLO: W-699mm(27.5") H-1003mm(39.5")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 ASTM E1886-05 ASTM E1996-05/09	Class R-PG50 1600 x 1118 (63 x 44)-HS Design Pressure: ± 2400 Pa (± 50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.5 psf) Wind Zone 3 - Missile Level D

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-4128-04
Expiration Date: October 31, 2027

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com