

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016193-R1
DATE: 05/20/2024
CERTIFICATION PROGRAM: Structural
COMPANY: Renaissance
CODE: 2592-1
REVISION DATE: 07/23/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Renaissance Windows & Doors, Inc. 13340 International Parkway Jacksonville, FL 32218	Series "8700" Vinyl Horizontal Sliding Window (Retrofit & Nail Fin Frame) Configuration: XOX Glazing: Insulating Glass (Annealed) Frame: W-2819mm(111") H-1600mm(63") Vent: W-918mm(36.13") H-1532mm(60.31") DLO: W-841mm(33.13") H-1456mm(57.31")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class R-PG25 2819 x 1600 (111 x 63)-HS Design Pressure: 1200 Pa (25 psf) Positive Design Pressure: 1440 Pa (30 psf) Negative Design Pressure: 1440 Pa (30 psf) Water Penetration Resistance Test Pressure: 180 Pa (3.76 psf)

Product Tested By: PRI Construction Materials Technologies, LLC
Report No: 2616T0007
Expiration Date: March 31, 2028

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023