

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI016193.01-R1  
**DATE:** 05/30/2024  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Renaissance  
**CODE:** 2592-1  
**REVISION DATE:** 07/23/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS                                                                                                    | PRODUCT DESCRIPTION                                                                                                                                                                                                                                                                             |
|-----------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>Renaissance Windows &amp; Doors, Inc.</b><br><br><b>13340 International Parkway</b><br><br><b>Jacksonville, FL 32218</b> | <b>Series "8700"</b><br><br><b>Vinyl Horizontal Sliding Window</b><br><br><b>(Retrofit Frame)</b><br><br>Configuration: OX<br>Glazing: Insulating Glass (Annealed)<br><br>Frame: W-1880mm(74") H-1600mm(63")<br>Vent: W-918mm(36.13") H-1532mm(60.31")<br>DLO: W-841mm(33.13") H-1456mm(57.31") |

| SPECIFICATION                          | PRODUCT RATING                                                                                                                                              |
|----------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b> | <b>Class R-PG40 1880 x 1600 (74 x 63)-HS</b><br><b>Design Pressure: ±1920 Pa (±40 psf)</b><br>Water Penetration Resistance Test Pressure: 290 Pa (6.06 psf) |

Product Tested By: PRI Construction Materials Technologies, LLC  
Report No: 2616T0006  
Expiration Date: **April 30, 2028**

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023