

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016618.01
DATE: 04/22/2025
CERTIFICATION PROGRAM: Structural
COMPANY: Renaissance
CODE: 2592-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Renaissance Windows & Doors, Inc. 13340 International Parkway Jacksonville, FL 32218	Series "10400" Vinyl Fixed Window (Retrofit & Nail Fin Frame) Configuration: O Glazing: IG-Ext. 3/16" Tempered Glass/Int. 1/8" Annealed Glass/0.090" Kuraray SG Interlayer/1/8" Annealed Glass Frame: W-1346mm(53") H-1930mm(76") DLO: W-1260mm(49.63") H-1845mm(72.63")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure: ± 2640 Pa (± 55 psf) Water Penetration Resistance Test Pressure: 470 Pa (9.82 psf) Large Missile Impact Rated

Product Tested By: PRI Construction Materials Technologies, LLC
Report No: 2616T0015
Expiration Date: February 28, 2029

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023