

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014624-R1
DATE: 01/16/2020
CERTIFICATION PROGRAM: Structural
COMPANY: Sunset Windows
CODE: 2348-1
REVISION DATE: 10/24/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Sunset Windows and Doors, LLC 910 Warehouse Road, Unit 110104 Orlando, FL 32803	Series "AL 580" Aluminum 58mm Outswing Side-Hinged Door Configuration: X Glazing: Insulated Glass (Tempered) Frame: W-1219mm(48") H-2438mm(96") Panel: W-1159mm(45.63") H-2375mm(93.5") DLO: W-959mm(37.75") H-2184mm(86")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08	Class AW-PG50 1219 x 2438 (48 x 96)-SHD Design Pressure: ± 2400 Pa (50 psf) Water Penetration Resistance Level: 648 Pa (13.5 psf)

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-4130-03
Expiration Date: April 30, 2033

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com