

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014627-R1
DATE: 01/16/2020
CERTIFICATION PROGRAM: Structural
COMPANY: Sunset Windows
CODE: 2348-1
REVISION DATE: 10/24/2022

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Sunset Windows and Doors, LLC 910 Warehouse Road, Unit 110104 Orlando, FL 32803	Series "V-750" Vinyl Casement Window Configuration: X Glazing: Insulated Glass (Tempered) Frame: W-914mm(36") H-1829mm(72") Panel: W-841mm(33.13") H-1756mm(69.13") DLO: W-686mm(27") H-1600mm(63")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08	Class CW-PG40 914 x 1829 (36 x 72)-C Design Pressure: ±1920 Pa (40 psf) Water Penetration Resistance Level: 288 Pa (6.0 psf)

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-4130-08
Expiration Date: January 31, 2033

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com