# NOTICE OF PRODUCT CERTIFICATION

| | |
|---|---|
| **CERTIFICATION NO:** | **NI014557.06-R4** |
| **DATE:** | **12/02/2019** |
| **CERTIFICATION PROGRAM:** | **Structural** |
| **COMPANY:** | **Pella** |
| **CODE:** | **1735-1** |
| **REVISION DATE:** | **04/20/2026** |

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|---|---|
| **Pella Corporation**<br>**102 Main Street**<br>**Pella, IA 50219** | **Series "Pella Entry Doors"**<br>**Impact Flush Glazed Fiberglass**<br>**In-Swing Door**<br>**w/Impact Sidelights & Composite Frame**<br>Configuration: OXXO<br>Glazing: IG- 1/8" Tempered Glass/1/8" Heat Strengthened Glass/0.090" Solutia Saflex Interlayer/1/8" Heat Strengthened Glass<br>Frame: W-3785mm(149") H-2480mm(97.63")<br>Panel: W-908mm(35.75") H-2413mm(95")<br>DLO: W-635mm(25") H-2007mm(79") |

| SPECIFICATION | PRODUCT RATING |
|---|---|
| **ASTM E330-02/14**<br>**ASTM E1886-05/12/13a**<br>**ASTM E1996-09/12a/14a/17** | **Design Pressure: +45/-45 psf**<br>**Missile Level D** |

Product Tested By: American Test Lab, Inc.
Report No: ATLNC 0427.01-15/ATLNC 0602.01-15/W-1977/W-2163
Expiration Date: **May 31, 2031**

Administrator's Signature: _____


**NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.**
**4794 George Washington Memorial Highway**
**Hayes, VA 23072**
**Tel: (804) 684-5124**
**Email: nami@namiinc.com**