NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI014620.05-R4**
DATE:	**01/08/2020**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Pella**
CODE:	**1735-1**
REVISION DATE:	**04/20/2026**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Pella Corporation **102 Main Street** **Pella, IA 50219**	**Series "Pella Entry Doors"** **Impact Glazed Fiberglass Out-Swing Door** **w/Sidelites & Composite Frame** Configuration: OXXO Glazing: IG-1/8" Tempered Glass/1/8" Heat Strengthened Glass/0.090" Saflex PVB Interlayer/1/8" Heat Strengthened Glass Frame: W-3785mm(149") H-2054mm(80.88") Panel: W-908mm(35.75") H-2006mm(79") DLO: W-533mm(21") H-1600mm(63")

SPECIFICATION	PRODUCT RATING
ASTM E330-02/14 **ASTM E1886-05/12/13a** **ASTM E1996-09/12a/14a/17**	**Design Pressure: +50/-50 psf** **Missile Level D**

Product Tested By: American Test Lab, Inc.
Report No: ATLNC 1222.01-15/ATLNC 0207.01-17/ATLNC 1012.01-16R/ATLNC 0907.01-16/W-1977/W-2163
Expiration Date: **May 31, 2031**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com