

AUTHORIZATION FOR PRODUCT CERTIFICATION

Peerless Products, Inc.
P.O. Box 431
Fort Scott, KS 66701

Attn: Coby Jones

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of tests by an AAMA Accredited Laboratory. The listing below will be added to the next update to the AAMA Certified Products Directory.

SPECIFICATIONS		RECORD OF PRODUCT TESTED		
AAMA/WDMA/CSA 101/I.S.2/A440-08 CW-PG70-1829x1829 (72x72)-FW	PA 201, 202, 203			
COMPANY AND PLANT LOCATION	Missile Level: Large Rating: +70/-70, 72x72	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED
Peerless Products, Inc. Code: PP	Rating above conforms to requirements of: TAS 201, TAS 202 and TAS 203	18660	G845 TWIN PICTURE WINDOW (AL) (O.O) (IG) (REINF) (INS PVB LAM GL) (ASTM)	<u>FRAME(mm)</u> 1829 x 1829 (6'0" x 6'0")

1. This Certification will expire **June 12, 2024** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

2. Product Tested and Reported by:

Intertek B&C

Report No.: **J6479.02-801-47 R0**

Date of Report: **September 11, 2019**

Missile Impact Test & Report by:

Intertek B&C

Report No.: **K3319.01-801-18 R1**

Date of Report: **November 21, 2019 (Revised Dec. 16, 2019)**



(Validator / Operations Administrator)

Evaluated for Certification: **January 3, 2020**



Associated Laboratories, Inc.

Authorized for Certification: **January 3, 2020**



Fenestration and Glazing Industry Alliance